

GENERAL NOTES

- 1. ALL CONCRETE SHALL BE F'c 25Mpa AT 28 DAYS.
- 2. PITS DEEPER THAN 750mm SHALL BE FITTED WITH GALVANIZED STEP IRONS (SPACE @ 300mm C.T.S) REFER TO STD YSD13 FOR FURTHER DETAILS.
- 3. THE FLOOR OF THE PIT SHALL BE FORMED UP TO AT LEAST THE SPRINGING LINE.
- CONCRETE TO BE VIBRATED IN PITS TO ENGINEER SATISFACTION.
- 5. CONCRETE TO BE POURED INTO PITS DIRECTLY OUT OF SUPPLY VEHICLES.
- BEDDING MATERIAL SHALL BE 100mm COMPACTED THICKNESS OF CLASS 2 C.R.
- 7. F72 REINFORCEMENT IN WALLS OVER 2m DEEP.
- 8. GRATE PERPENDICULAR TO KERB AND CHANNEL.
- 9. FOR GATIC COVER B145 OR EQUIVALENT REFER MANUFACTURERS STANDARD DRAWING DETAILS.
- 10. COVER TO BE MADE LEVEL WITH SURFACE OR AS DIRECTED BY THE ENGINEER.
- 11. CONTRACTOR TO SUPPLY ALL MATERIALS.

Yarra Standard: YSD11 Drawing Title:

JUNCTION PIT WITH GATIC OR EQUIVALENT COVER

Scale at A4 N.T.S Updated 29/11/07



Richmond Town Hall 333 Bridge Road Richmond PO Box 168 Richmond 3121 Phone (03) 9205 5010 Fax (03) 8417 6666