



4% CEMENT TREATED
CRUSHED ROCK
CLASS 2



25MPa CONCRETE
100mm THICK

GENERAL NOTES

1. PITCHERS ARE NOMINALLY 300*225*150mm.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH COUNCILS SPECIFICATION " CONSTRUCTION OF PITCHER KERB & CHANNEL AND PRAM CROSSINGS".
3. DAMAGED AND UNSUITABLE BLUESTONE BLOCKS(PITCHERS) TO BE REPLACED
4. INVERT TO BE FINISHED TO GRADE WITH WOODEN FLOAT. INVERT JOINT TO BE NOM. 35mm, OTHER JOINTS TO BE NOM. 15mm.
5. CEMENT TREATED CRUSHED ROCK BEDDING BELOW THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 90% OF THE MODIFIED AASHO VALUE. CEMENT TREATED CRUSHED ROCK IN FRONT OF THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 95% OF THE MODIFIED AASHO VALUE.

Yarra Standard: YSD56 Drawing Title:

BLUESTONE RAMP FOR
INTERSECTION TREATMENT
FOOTPATH AT GRADE

Scale at A4 N.T.S
Updated 27/11/07

