



GENERAL NOTES

1. A.G PIPES FOR THIS WORK SHALL BE THE SIZE AND TYPE SHOWN ON THIS DRAWING AND SHALL COMPLY WITH THE CURRENT AUSTRALIAN STANDARDS AND THE MANUFACTURES SPECIFICATION.
2. FILLER MATERIALS FOR USE IN BACKFILLING TRENCHES, AROUND AND OVER PIPES SHALL CONSIST OF "NO FINE CONCRETE" OF SIZE 20 ONE SIZE AGGREGATE MIXED WITH 4% BY MASS OF CEMENT AND 3.5% BY MASS OF WATER IN AN APPROVED MIXING PLAN. THE AGGREGATE SHALL COMPLY WITH THE RELEVANT REQUIREMENT OF VICROADS STD SPECIFICATION SECTION 702.
3. TRENCHES SHALL BE EXCAVATED TO THE DIMENSIONS AND GRADE REQUIRED BY THE DRAWINGS OR AS DIRECTED BY THE SUPERINTENDENT. A BEDDING LAYER OF NOT LESS THAN 50mm COMPACTED DEPTH OF FILLER MATERIAL SHALL BE PLACED IN THE BOTTOM OF THE TRENCH FOR ITS FULL LENGTH AND WIDTH . A.G PIPE SHALL THEN BE LAID TRUE TO LINE AND GRADE AND FIRMLY EMBEDDED IN THE BEDDING MATERIAL WITH ADJACENT LENGHTS BOLTED TOGETHER OR CONNECT WHERE NECESSARY. AFTER THE A.G PIPE INSTALLATION HAS BEEN INSPECTED AND APPROVED, THE FILLER MATERIALS SHALL BE PLACED TO THE HEIGHT SPECIFIED ON THIS DRAWING.

Yarra Standard: YSD8 Drawing Title:

INSTALLATION OF SLOTTED PVC
AGRICUTURAL DRAINS (A.G DRAIN)

Scale at A4 N.T.S
Updated 27/11/07

